



Southwest Clean Air Agency

11815 NE 99th Street, Suite 1294 • Vancouver, WA 98682-2322
(360) 574-3058 • Fax: (360) 576-0925
www.swcleanair.org

July 17, 2014

Susan Steinbrenner
Evergreen School District
PO Box 8910
Vancouver, WA 98668-8910

Subject: Notification of Boiler Installation at Crestline Elementary School – (SUN-057)

Dear Ms. Steinbrenner:

The Southwest Clean Air Agency (SWCAA) received your Small Unit Notification (SUN) on July 8, 2014 for installation and operation of a new boiler at Crestline Elementary. The new boiler will provide hydronic heating to the new school building. For administrative and tracking purposes SWCAA has assigned tracking number SUN-056 to this notification. This notification was filed in accordance with SWCAA 400-072 and applies to the installation of one boiler. The new boiler was identified as:

- (1) Hydrotherm model KN-20, natural gas fired condensing boiler with a rated heat input capacity of 1.999 MMBtu/hr. The boiler will be identified as "Boiler #2".

SWCAA has completed a review of your notification and the associated support information and has determined that the notification meets the requirements of SWCAA 400-072(2). Once installed, affected equipment must maintain compliance with the requirements of SWCAA 400-072(4)(b) "**Small gas fired boilers/heaters**". A copy of the relevant SWCAA 400-072 section is attached for your information. SWCAA 400-072(4)(b)(v) requires that emissions from the unit be tested within 60 days of initial operation and annually thereafter. Subsequent annual emissions monitoring may be conducted utilizing the schedule approved by SWCAA in a letter dated May 1, 2008. SWCAA's May 1, 2008 letter allows Evergreen School District to conduct all annual testing no later than March 31st of each year, unless another alternate schedule is approved in advance by SWCAA. Each month's test results must be submitted to SWCAA by the 15th of the following month.

Be advised that emission units installed pursuant to SWCAA 400-072 are subject to source registration and periodic inspection. Registration fees for this equipment will be invoiced consistent with SWCAA 400-100.

If you need further assistance or have any questions regarding these matters, please contact me at (360) 574-3058 extension 130.

Sincerely,

Paul T. Mairose
Chief Engineer

cc: Mr. Mark Northington
Evergreen School District No. 114
PO Box 8910
Vancouver, WA 98668-8910



SWCAA 400-072 Emission Standards for Selected Small Source Categories

[Statutory Authority: Chapter 70.94.141 RCW. Original adoption 09-21-056 filed 10/15/09, effective 11/15/09.]

(4) Source categories.

(b) Small gas fired boilers/heaters.

- (i) **Applicability.** The provisions of this section apply to gas fired (natural gas/propane/LPG) boilers and heaters with individual rated heat inputs equal to or greater than 0.4 MMBtu/hr and equal to or less than 2.0 MMBtu/hr. For the purposes of this subsection, the term "boiler" means any combustion equipment designed to produce steam or to heat water that is not used exclusively to produce electricity for sale.
- (ii) **Emission limits and standards.**
 - (A) Visible emissions from the boiler exhaust stack shall not exceed zero percent opacity for more than 3 minutes in any one hour period as determined in accordance with SWCAA Method 9. (SWCAA 400, Appendix A).
 - (B) Each boiler/heater shall be equipped with combustion technology capable of maintaining NO_x and CO emissions at, or below, 30 ppmv and 50 ppmv, respectively (corrected to 3% O₂, dry).
- (iii) **General requirements.**
 - (A) Each boiler/heater shall only be fired on natural gas, propane, or LPG.
 - (B) Boiler/heater exhaust shall be discharged vertically above the roof peak of the building in which the emission unit is housed, and at a point higher than surrounding buildings. Any device that obstructs or prevents vertical discharge is prohibited.
- (iv) **Monitoring and recordkeeping requirements.** The information listed below shall be recorded at the specified intervals, and maintained in a readily accessible form for a minimum of 3 years. With the exception of data logged by a computerized data acquisition system, each required record shall include the date and the name of the person making the record entry.
 - (A) Quantity of fuel consumed by the boiler/heater shall be recorded for each calendar month;
 - (B) Maintenance activities for the boiler/heater shall be logged for each occurrence;
 - (C) Upset conditions that cause excess emissions shall be recorded for each occurrence; and
 - (D) All air quality related complaints received by the permittee and the results of any subsequent investigation or corrective action shall be recorded for each occurrence.
- (v) **Testing requirements.**
 - (A) Each boiler/heater shall undergo emission monitoring no later than 60 calendar days after commencing initial operation. Subsequent monitoring shall be conducted annually thereafter no later the end of the month in which the original monitoring was conducted. An alternate monitoring schedule may be implemented, but must be approved by the Agency prior to use. All emission monitoring shall be conducted in accordance with the requirements of SWCAA 400-106(2).
 - (B) If emission monitoring results for a boiler/heater indicate that emission concentrations may exceed 30 ppmvd NO_x or 50 ppmvd

CO, corrected to 3% O₂, the owner or operator shall either perform 60 minutes of additional monitoring to more accurately quantify CO and NO_x emissions, or initiate corrective action. Corrective action shall be initiated as soon as practical but no later than 3 business days after the potential exceedance is identified. Corrective action includes burner tuning, maintenance by service personnel, limitation of unit load, or other action taken to lower emission concentrations. Corrective action shall be pursued until observed emission concentrations no longer exceed 30 ppmvd NO_x or 50 ppmvd CO, corrected to 3% O₂.

(vi) **Reporting requirements.**

- (A) All air quality related complaints received by the owner or operator shall be reported to the Agency within 3 business days of receipt.
- (B) Emission monitoring results for each boiler/heater shall be reported to the Agency within 15 calendar days of completion on forms provided by the Agency.
- (C) The owner or operator of an affected boiler/heater shall report the following information to the Agency no later than March 15th for the preceding calendar year:
 - (I) Quantity of fuel consumed; and
 - (II) Air emissions of criteria air pollutants, VOCs, and toxic air pollutants (TAPs).